

CERTIFICATE

Ship: SSRS 16-01 ODD FELLOW Call Sign: SGZN

Home Port: BUA

AEROSOL EXTINGUISHING SYSTEM

We hereby certify that the FIRE-PRO AEROSOL EXTINGUISHING SYSTEM for ENGINE ROOM this day have been checked on board the SSRS 16-01 ODD FELLOW in Bua.

The Plant have been left in Good and Working Condition.

2 pcs Container FP 2000.

Installation date of containers: 2017.

Wire operated release system.

Automatic emergency fan stops.

Fire detection central: Genesis II

5 pcs Smoke detectors.

Type of certificate: Total System Control (see reverse side)

Next service 2024-06

Gothenburg 2023-06-14

Presto AB



Jonas Lindahl



RINA



Type of certificate

Total System Control, includes checking of (when applicable):

- Content of container.
- Release wires.
- Electronic release system.
- Warning alarms
- Fanstops
- Initiators
- Connections
- Release function test
- Control units
- Mechanical fitting
- Signs
- Rust damages etc.